

ADDENDUM NUMBER 2

SEDALIA, MO
COME GROW WITH US

Title: Storm Drainage Improvements – Project Area 14
Owner: City of Sedalia, Missouri
Engineer: Wilson & Company, Inc., Engineers & Architects

ISSUE DATE: **February 2, 2024**

Bidders are hereby notified of the following changes, additions, modifications, information and clarification for the above project, for which Bids are to be received on Wednesday, **February 7, 2024**, at 3:00 PM are amended as follows:

QUESTIONS AND CLARIFICATIONS

1. Can you identify the size of the waterlines to be relocated?
 - a. *The water main sizes according to GIS are 2", 6", and 8". There were no potholes performed to confirm these sizes though and it shall be the Contractor's responsibility to confirm pipe sizes.*
2. There seems to be many conflicts with the existing gas mains and service lines. Are there any relocation plans by Liberty or Empire Gas in place at this time?
 - a. *Liberty is aware of the projects and the potential relocation needs. They will work with the City and Contractor to complete relocations as necessary.*
3. I can't find a clear spec on what Turf Reinforcement Mat is required. Can you provide me with any direction?
 - a. *Turf Reinforcement Mat shall follow KC Metro APWA Specifications section 2153.9. The Turf Reinforcement Mat shall be Class 2, Type F.*

PLANS

1. No Changes

PROJECT MANUAL

1. No Changes

NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the Proposal.