

ADDENDUM NUMBER 2

SEDALIA, MO
COME GROW WITH US

Title: Storm Drainage Improvements – Project Area 21
Owner: City of Sedalia, Missouri
Engineer: Wilson & Company, Inc., Engineers & Architects

ISSUE DATE: **February 2, 2024**

Bidders are hereby notified of the following changes, additions, modifications, information and clarification for the above project, for which Bids are to be received on Wednesday, **February 7, 2024**, at 2:30 PM are amended as follows:

QUESTIONS AND CLARIFICATIONS

1. Can you identify the size of the waterlines to be relocated?
 - a. *The water main size according to GIS is 6". There were no potholes performed to confirm these sizes though and it shall be the Contractor's responsibility to confirm pipe sizes.*
2. There seems to be many conflicts with the existing gas mains and service lines. Are there any relocation plans by Liberty or Empire Gas in place at this time?
 - a. *Liberty is aware of the projects and the potential relocation needs. They will work with the City and Contractor to complete relocations as necessary.*

PLANS

1. No Changes

PROJECT MANUAL

1. No Changes

NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the Proposal.