

# ADDENDUM NUMBER 2

**SEDALIA, MO**  
COME GROW WITH US

**Title:** Storm Drainage Improvements – Project Area 35  
**Owner:** City of Sedalia, Missouri  
**Engineer:** Wilson & Company, Inc., Engineers & Architects

ISSUE DATE: **February 2, 2024**

Bidders are hereby notified of the following changes, additions, modifications, information and clarification for the above project, for which Bids are to be received on Wednesday, **February 7, 2024**, at 3:30 PM are amended as follows:

## **QUESTIONS AND CLARIFICATIONS**

1. Can you identify the size of the waterlines to be relocated?
  - a. *The water main size according to GIS is 2". There were no potholes performed to confirm these sizes though and it shall be the Contractor's responsibility to confirm pipe sizes.*
2. There seems to be many conflicts with the existing gas mains and service lines. Are there any relocation plans by Liberty or Empire Gas in place at this time?
  - a. *Liberty is aware of the projects and the potential relocation needs. They will work with the City and Contractor to complete relocations as necessary.*

## **PLANS**

1. No Changes

## **PROJECT MANUAL**

1. No Changes

**NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the Proposal.**