Addendum No 1
2027-012

The City of Sedalia received the following questions:

-For clarification at the Glass Pulverizer location how are we to terminate the 200 amp 3 phase feeder for protection of the installed conductors for future connection to the equipment? A local non fused disconnect on an equipment rack or a junction box? Yes, a rack with main shut off

-Has the city made application to the utility company for the new service and the engineering fee paid to determine the associated costs? No

-Will the city be responsible for the utility fees associated with the new service? Yes