Addendum No 2
2027-012

The City of Sedalia received the following questions:

1. Can the City provide a scaled site layout, service and feeder lengths, and the pulverizer's location and nameplate information? See map contained in IFB and the IFB states for future installation of a pulverizer.
2. Who is the serving utility and contact? Is an approved service and metering design available, including whether CT or self-contained metering is required, service-lateral ownership, and available fault current? This would be determined by Evergy.
3. What are the required rack and main-shutoff ratings, and what will the second 200-amp breaker serve? Must comply with City code and the requirements of an Andela model GP-1HD 10 TPH
4. Please clarify responsibility for trenching, bedding, concrete, bollards and site restoration. Contractor
5. What prevailing-wage or Davis-Bacon determination applies, and what is the project's funding source? If applicable Wage Order 33 would apply. Funding source is through a Region F Solid Waste District grant and City funds.
6. What is the desired construction schedule, and who is responsible for coordinating utility energization? Start in December or January and the Contractor.
7. The documents appear to specify both 90- and 120-day bid validity. Which applies, and what forms of the 5% bid guarantee are accepted? 120 day and the guarantee forms accepted are surety bond with a POA or check.
8. Is bidder registration required, and how can we arrange site access? No it is not and contact Justin Bray at Public Works Operations Director at 660-620-5527.