Addendum No 3
2027-012

The City of Sedalia received the following question:

Can Aluminum Conductors be used or do the Conductors need to be Copper? The conductors need to be copper.